



Saturday, April 6, 2024

Norman Public Library -Central

103 W Acres St

Norman, OK 73069

Water Loss/Intrusion Investigation and monitoring:

On Saturday, April 6, 2024, around 5:00 pm, we received wind-driven rain in central Norman. David Serna and Gary Cavins were dispatched to the Central Library for a water intrusion site inspection. During the inspection, they found some areas of concern. We discovered water intrusion in Pioneer Room 305, specifically in the south-west corner ceiling area, over the north conference labs.

Also, the second floor by the bay windows on the south side of the building has three window areas that are leaking. The break room has a window leak on the north center window, a trashcan was placed under it, the trashcan had approximately two gallons of water in it from the leakage. The first floor in the children's Area had some signs of leakage below the green roof, not a considerable amount of water.

Additionally, the south stairs on the third floor had water on the inside landing for the roof access door. None of these areas needed structural drying or water extraction at this time. There was not enough water intrusion to warrant additional services, the water diversion systems Cavins Group set up also collected the water in these areas.

A formal report will be issued along with this inspection summary letter.

Respectfully,

Cavins Group LLC

Cavins Group
Water // Fire // Mold // Crime Scene
1839 Atchison Dr., Norman, OK 73069
Norman (405) 573-3048 // Tulsa (918) 282-7612