

Date Tue 09/03/2024

Job #

Weather

6:00 AM

69° 

Partially cloudy

Wind: 6 MPH | Precipitation: .0" | Humidity: 79%

12:00 PM

74° 

Partially cloudy

Wind: 6 MPH | Precipitation: .0" | Humidity: 77%

4:00 PM

79° 

Partially cloudy

Wind: 0 MPH | Precipitation: .0" | Humidity: 65%


Work Logs

Name	Description
Cavins Environmental	<p>Monthly air quality testing was performed in the common areas of the Norman Public Central Library. Five interior samples and one exterior control sample were taken. The spore trap samples will be delivered to the lab for analysis.</p> <p>The humidity in the facility remains slightly elevated. Although it is still at or below 50%, given the history of microbial growth and ongoing water intrusion, it is highly advised that the humidity be better controlled in the indoor environment.</p>
Total	

General Notes

1. First Floor Common Area:

One spore trap sample was taken. Humidity is slightly elevated at 47.9% temperature is 74.3°.










2. Children's Area:
One spore trap sample



3. Second Floor Common Area:
One spore trap sample was taken.




4. Stairwell:
One spore trap sample was taken in the stairwell





5. Third Floor Common Area:
One spore trap sample was taken



6. Outside - 1 exterior control sample was taken humidity 74.7% Temperature 74.4 degrees



