

**ADDENDUM NO. 1  
TO THE BID PACKAGE  
for the  
BOYD STREET STORM SEWER REPLACEMENT  
CITY OF NORMAN**

**To all Planholders and/or Prospective Bidders**

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the construction of the Boyd Street Storm Sewer Replacement Project:

Addendum No. 1 provides for changes in the original Bid Package (Bid No. 2425-26) and issues new Specifications and Contract Documents. Addendum No. 1 also provides clarification and answers to Contractor questions received at and after the pre-bid conference. Addendum No. 1 consists of the following:

**SPECIFICATIONS AND CONTRACT DOCUMENTS**

1. Pay Item No. 4 – Manhole (6’ Diameter) 5 each reduced from Total Quantity
2. Pay Item No. 48 – 50 C.Y. - P.C. Concrete (3500 PSI) added to the Pay Items.
3. Pay Item No. 49 – 5 Each - Manhole (8’ Diameter) added to the Quantity.
4. Utility Bracing Note – # 14 Pay Item Note edited
5. Concrete Note – # 17 Added to the Pay Item notes
6. Add Alternate 1 Note – #18 Pay Item Note Edit form number 1 to number 18.
7. General Notes – 2 Additional General notes added to the list.
8. Add Alternate Pay Items notes #1 and #2 – Pay Item Note number edited
9. Sheet C-203 – Revisions – Change 6’ diameter manhole to 8’ diameter manhole.
10. Sheet C-204 – Revisions - Change 6’ Diameter Manhole to 8’ Diameter Manhole
11. Sheet C-204 – Revisions – Added 18” RCP
12. Sheet C-204 – Revisions – Revised Ex. Sanitary Sewer Manhole Data to Storm Sewer Pipe
13. Sheet C-205 – Revisions – Changed 6’ Diameter Manhole to 8’ Diameter Manhole.

**CLARIFICATION**

1. The Start Date for the project will be delayed until **May 19, 2025**.
2. If the add alternate is accepted, the mill and overlay can be completed at one time provided a traffic control plan is submitted and approved.
3. Concerning dewatering - There is no geotechnical report. We anticipate ground water at the downstream side due to the proximity to the creek.
4. After the placement of the surge rock (if necessary) the compaction requirements shall meet the City of Norman Standards.
5. Conditions will require examination prior to authorization of any additional placement of surge rock for the construction of a suitable base for the new storm sewer.

Please revise your bid proposal to reflect these changes.

**END OF ADDENDUM  
ACKNOWLEDGEMENT OF ADDENDUM NO. 1**

Acknowledgment of receipt of this Addendum must be made in the Proposal. Bids submitted without this acknowledgment will be considered informal.

Receipt of Addendum No. 1 is acknowledged and its conditions agreed to:

Bidder \_\_\_\_\_

By \_\_\_\_\_

Date \_\_\_\_\_